

AN ORDINANCE APPROVING A PROPOSAL WITH GE STEAM POWER, INC.
FOR THE INSPECTION OF THE UNIT NO. 33 TURBINE-GENERATOR
FOR THE OFFICE OF PUBLIC UTILITIES, FOR EMERGENCY PASSAGE

WHEREAS, on November 12, 2019, Dallman Power Plant Unit 33 Turbine-Generator suffered a failure, and

WHEREAS, due to this failure, damage was done to all turbine bearings and seals on Unit 33, and

WHEREAS, this ordinance accepts a proposal with GE Steam Power, Inc., a copy of which will be on file with the Office of the City Clerk, for turbine-generator inspection services including labor, supervision, field engineering, materials and tools necessary to perform the inspection at the Dallman Power Plant Unit 33 turbine-generator, and

WHEREAS, GE Steam Power, Inc. is the original equipment manufacturer and is the sole source vendor capable of providing said turbine inspection services, and

WHEREAS, pursuant to the provisions of Section 38.40 of the City Code, the Purchasing Agent has determined that this contract is not subject to sealed competitive bidding.

NOW, THEREFORE, BE IT ORDAINED BY THE COUNCIL OF THE CITY OF SPRINGFIELD, ILLINOIS:

Section 1. The Council of the City of Springfield, Illinois, hereby approves and accepts the proposal with GE Steam Power, Inc. for the turbine inspection of the Dallman Power Plant Unit No. 33 Turbine-Generator for the Office of Public Utilities Electric Division in the total amount not to exceed TBD (\$TBD).

Section 2. The Mayor and the City Clerk are hereby authorized and empowered to execute said Proposal and any necessary documents for the inspection on Dallman Unit 33 turbine-generator on behalf of the Office of Public Utilities.

Section 3. Payment by the Office of Budget and Management to GE Steam Power, Inc. for the total amount not to exceed TBD (\$TBD) from Account No. 102-100-CAA-7712-1205 is hereby authorized, approved and directed.

Section 4. This Ordinance shall become effective immediately upon its passage and recording with the City Clerk.

PASSED: _____, 2019

SIGNED: _____, 2019

RECORDED: _____, 2019

MAYOR

ATTEST: _____

Approved as to legal sufficiency:



Office of the Corporation Counsel/Date

Requested by the Office of Public Utilities/Mayor Langfelder

ORDINANCE FACT SHEET

AGENDA NUMBER: _____
DATE OF 1ST READING: 11-19-19
ORDINANCE REQUEST NUMBER: GFE-304

DEPARTMENTAL INFORMATION

OFFICE REQUESTING: PUBLIC UTILITIES

STAFF MEMBER: MICHELLE CARLISLE

EMERGENCY PASSAGE: YES/NO If yes, list justification.

Due to a failure on November 12, 2019, Unit 33 suffered damage to all turbine bearings and seals. Approval of this contract will allow repairs to be made so the Unit can come back online.

BUDGETARY/STAFFING INFORMATION

FISCAL IMPACT: \$ TBD BUDGETED: YES/NO NEW POSITION: YES/NO

STAFFING IMPACT: None

TYPE OF ORDINANCE: Sole Source / OEM

ACCOUNTING INFORMATION: 102-100-CAA-7712-1205

VENDOR/AWARD INFORMATION

CONTRACTOR NAME: GE Steam Power, Inc. CONTRACT AMOUNT: \$ TBD
(Original Amount if Change Order)

CONTRACT TERM: until completion TYPE OF AWARD: Sole Source

CHANGE IN SCOPE Y X N CHANGE ORDER # N/A ADDT'L AMOUNT \$ 0.00

STAFF ANALYSIS: (This includes description of work, background on issue and the justification of why the ordinance was not low bid. If you need additional space, please continue on the back of this form.)

This is an emergency passage requested ordinance to authorize and approve GE Steam Power, Inc. to perform inspections to Unit 33 Turbine/Generator. Unit 33 suffered a failure causing damage to all turbine bearings and seals. There is suspected additional damage to turbine blade and potential generator damage that is unknown currently.

GE Steam Power, Inc. is the original equipment manufacturer. GE Steam Power, Inc. is not a local vendor.

SIGN OFF: _____ Mayor's Office _____ OBM
(When Applicable)

Rev: 6-21-96 The information supplied on this form is not confidential information.